Advancements in Nuclear Instrumentation Measurement Methods and their Applications 20-24 April 2015, Lisbon Congress Center



# A Cylindrical GEM Detector with Analog Readout for the BESIII Experiment

Gianluigi Cibinetto
(INFN Ferrara)
on behalf of the CGEM BESIII group





#### **Outline**

- The BES III experiment
  - the Inner tracker
- The Gas Electron Multipliers
- The BESIII Cylindrical GEM-IT
  - innovations and peculiarities
  - construction of a cylindrical layer
  - test beam with a planar prototypes
- Project status and schedule
- Summary and Conclusions






# The BES III experiment



### BESIII: a τ-charm factory


BES-III (Beijing Spectrometer III) is  $\tau$ -charm factory located at the Beijing e+e-collider BEPC-II working in the energy range from 2 GeV to 4.6 GeV.




Very rich physics program: Charm, charmonium and exotic states spectroscopy, light hadrons, F.F.,  $\tau$  physics.




#### **BEPCII** at IHEP



#### BEPCII storage rings





Upgrade of BEPC (started 2004, first collisions July 2008)

Beam energy 1...2.3 GeV
Optimum energy 1.89 GeV
Single beam current 0.91 A
Crossing angle ±11 mrad

Design luminosity  $10^{33} \, \text{cm}^{-2} \text{s}^{-1}$ Achieved  $8 \times 10^{32} \, \text{cm}^{-2} \text{s}^{-1}$ Beam energy measurement:

Laser Compton backscattering

 $\Delta$ E/E  $\approx 5 \times 10^{-5}$ ( $\approx 50 \text{ keV at } \tau \text{ threshhold}$ )

#### The BESIII detector

**Multilayer Drift Chamber** Time-of-flight, 90ps 120 mm 0.5% at 1 GeV/c Be beam pipe


Angular coverage

- 93% of  $4\pi$  for the tracking system
- 95% of  $4\pi$  for the calorimeter

Total weight 730 ton


~40,000 readout channels


Data rate: 5kHz, 50Mb/s






#### The dataset







- + 104 energy points between 3.85 and 4.59 GeV
- + ~ 20 energy points between 2.0 and 3.1 GeV (ongoing)

Direct production of 1— states studied with world's largest scan dataset


# Physics Highlights



Devin Powell

18 June 2013

Rights & Permissions



#### BESIII observes new mystery particle

In a striking and unexpected observation from new studies aimed at an understanding of the anomalous Y(4260) particle, the international team that operates the Beijing




BESIII spectrometer






3. Brain responds to tiniest speech Nature | 30 January 2014



#### The BESIII collaboration






# MDC-IT aging issue



#### The Multilayer Drift Chamber Inner Tracker




The increases of the luminosity is speeding up the aging the the inner tracker (IT).

The gain of the innermost layers is decreasing of about 4% per year of data taking.

BESIII will run at least up to 2022 → a replacement is needed.

- MDC performs momentum and dE/dx measurement for charged particle identification.
- Spatial resolution is 130 μm in r-φ plane (azimuthal) and 2 mm in the z-coordinate (polar).

Inner and Outer MDC are two separate chambers sharing the same gas volume.




# The Gas Electron Multipliers




#### GEM in a nutshell

A thin polymer foil, metalcoated on both sides, is chemically pierced by a high density of holes.

On application of a voltage gradient, electrons released on the top side drift into the hole, multiply in avalanche and transfer the other side.





Proportional gains above 10<sup>3</sup> are obtained in most common gases.

Cascaded GEMs permit to obtain larger gains


Spatial resolution determined by chamber and readout electrode geometries




## Cylindrical GEM detector

4 CGEM layers at 13/15.5/18/20.5 cm from IP inside outer Drift Chamber

- 700 mm active length
- XV strips-pads readout (25°÷30° stereo angle)
- 2% X<sub>0</sub> total radiation length in the active region including Carbon Fiber shield





The KLOE-2 Collaboration built the only existing CGEM based detector currently under commissioning.

Performance evaluation in progress.




# **CGEM Construction Technique**

To obtain cylindrical electrodes the foils are wrapped around molds, there is one mold for each of the 5 electrodes.




The electrode foils are first glued on a plane



3 GEM foils are spliced together with a 3 mm overlap and closed in a vacuum bag (0.9 bar)

Fiberglass supports are outside the active area




# **CGEM Assembly Technique**

- A dedicated assembling machine has been designed and realized to perform the insertion of the electrodes. BESIII will use the same machine.
- Axial alignment has a precision of 0.1mm/1.5m.
- The structure can rotate by 180° around its central horizontal axis one into the other.









# A Cylindrical GEM Inner Tracker for BES III experiment



#### The CGEM-IT






#### Requirements


- Rate capability: ~10<sup>4</sup> Hz/cm<sup>2</sup>
- Spatial resolution:  $\sigma_{xy}$  =~120 $\mu$ m :  $\sigma_z$ =~1 mm Momentum resolution::  $\sigma_{pt}/P_t$  =~0.5% @1GeV
- Efficiency = ~98%
- Material budget  $\leq 1.5\%$  of  $X_0$  all layers
- Coverage: 93% 4π
- Operation duration ~ 5 years




# Mechanical Design



The frontend electronics cards will be located in the dead space available between the layers outside the active area.








#### Peculiarities and innovations of the BES III design

- The innovative aspects are mainly related, but not limited, to the following three items:
  - the material used to give the mechanical rigidity to the detector structure (that will be Rohacell instead of Honeycomb);
  - the anode design: Compass-like with jagged-strip layout;
  - analog readout to achieve the required spatial resolution with a limited number of channels. The position is measured with charge centroid calculation.



#### The Rohacell structure




Rohacell is a very light material (density of 31 kg/m³) that will be replace the honeycomb in the cathode and anode construction with substantial reduction of the thickness of the detector.

	BESIII	KLOE-2
$\#$ of $X_0$ for 1 layer	0.33	0.49
$\#$ of $X_0$ for 3 layers	0.99	1.47

This technique has been successfully tested in Ferrara




### Test of the Rohacell technique









# The KLOE-2 anode design



Readout plane is realized at CERN TE-MPE-EM It is a kapton/copper multilayer flexible circuit Provides 2-dimensional readout with XV strips on the same plane

- •X are realized as longitudinal strips
- •V are realized by connection of pad through conductive holes and a common backplane
- •Pitch is 650 μm for both





X pitch 650µm → X res 190µm

with digital readout and ~0.5 T magnetic field

V pitch 650µm → Y res 350µm

25/10/2012 • 17


Presented by D. Domenici @ LNF CGEM workshop



## Compass anode design

**COMPASS:** readout electrodes

large strip capacitance ~100 pF




 Due to diffusion the charge cloud collected on the readout board is bigger than the strip width (≈ 3.5 x pitch) and a weighting method is used for calculate the exact track position in two dimensions BESIII anode will be Compass-like 650/570/130 µm (pitch, X, V); stereo angle depending on the layer geometry




X-COORDINATE


# Jagged strip design


A jagged-strip layout has been studied to minimize the strip capacitance:






capacitance reduce compared to the standard strip configuration





#### In addition:

- the ground will be kept at 2 – 4 mm from the strip plane
- support structure made of Rohacell





#### Frontend electronics

- The analog readout is mandatory to limit the number of electronics channels. The charge measurements is performed by a dedicated ASIC chip.
- Design of CGEM ASIC (UMC .11μm) starting from existing design (IBM .13μm)
  - BackEnd design shared by several projects
  - BackEnd porting to UMC .11 μ m in progress
  - Different input stage (suited for CGEM) to increase signal sensitivity and SNR
- FrontEnd Simulations
  - input stage optimized to handle capacitance in the range 20pF-150pF
     circuit tested with a delta-pulse and GEM-like signal.




# Main feature of the ASIC design

- UMC 110 nm technology
  - (limited power consumption, to be tested for radiation tolerance)
- Input charge: 3-50 fC
- Sensor capacitance 100-150 pF
- Input rate (single strip): 7-15 kHz
- Time and Charge measurements by independent TDCs
- TDC time binning > 50 ps  $\Rightarrow$  CGEM needed time resolution  $\sim 1 \text{ ns}$
- Double threshold discrimination
- Time over Threshold (ToT) to measure the charge 

  → CGEM: Linear ToT
- Power consumption < 7 mW p/channel ⇒ 4 mW p/channel feasible</li>


developed by INFN Turin

#### Overview of the FEE architecture




- Time and charge measurements with independent TDCs
- TDC time binning 50 ps
- Charge measured with Time-over-threshold
- Typ. power consumption is 7mW p/channel (trigger 0.5 p.e. w/ SNR > 23dB for 9  $mm^2$  MPPC, 40 KHz event rate, 1MHz DCR

# Toward the construction of a cylindrical layer





#### Cathode construction



• 12.5 micron kapton foil around the aluminum mold; that is the most critical part.

 the Rohacell plane is glued under vacuum on the kapton.



• the Rohacell plane is machined with a high precision milling machine.


Picture from INFN-Ferrara assembly site.



# **GEM** testing

Layer-2 GEM foils arrived from CERN and have been tested in the clean room.





GEM production quality test.

Before gluing, a HV test is performed on the GEM foils. Good GEM must satisfy both:

- <1 nA @ 600 V</p>
- <2 discharges/30mins</li>





Microscope pictures of GEM defects



## **GEM** assembly



- Pictures of GEM cylindrical assembly in the INFN-LNF clean room
- Plan to move to the vertical assembly next summer.





# Planar Detector Prototype Test Beam



# Test Beam with a planar prototype


- A test beam has been performed last December at CERN to:
  - Validate GEM analog readout in magnetic field.
  - Validate Garfield simulation and extract useful information for hit digitization.
- We performed the following measurements with different detector geometries:
  - Spatial resolution as function of the magnetic field
  - Cluster size as function of the magnetic field
  - Efficiency measurements at different gain
  - Test different gas mixture: Ar/CO<sub>2</sub> (70/30) and Ar/Isobutene (90/10)
  - Different incident beam angle: 0°/10°/30°/45°



### BESIII setup

We performed a beam test last December to test a planar prototype inside a magnetic field.


The BESIII prototype



Forward Tracking

Backward Tracking

#### **GOLIATH**



- validate analogue readout
- validate Garfield simulation
- test different gas and geometry configurations




## The test beam setup






### Some readout details

- The prototype is readout by Scalable Readout System developed by RD51 collaboration.
- The analog APV front-end ASIC combines a sensitive preamplifier, switchedcapacitor analog memory array, and low-voltage differential analog output buffer.




 Charge is sampled in 25 ns bins → possibility to combine charge and time information.



# Preliminary Results with no B field







## Efficiency and spatial resolution (no B field)


The efficiency plateau starts at about a gain of 6000.

Efficiency for 2 dimensional clusters ~97%.

Spatial resolution (micron) vs gain (V)







With 650  $\mu$ m strip pitch we achieved about 90  $\mu$ m of spatial resolution without magnetic field and Ar/Isob (90/10).

Studies with magnetic field ongoing.


Need for a new beam test to complete our measurements.



# Preliminary Results with B field



### Effect of the magnetic field on the electron avalanche





## Results with B field

 Effect of B field on cluster multiplicity and comparison with Monte Carlo simulation.




cluster size





Cluster Size vs B field (T)




 No effect of magnetic field on tracking efficiency.




## Exploring the GEM technology potentialities: µTPC readout


- The time information can be used to improve the spatial resolution with B field.
- Time information can be extracted from the sampling of the APV signal.



Fit to the charge samples to extract the drift time




#### difference from t<sub>2</sub> and t<sub>1</sub>






## μTPC readout feasibility study

#### Hit Time distribution for all clusters




- The electron drift velocity can be extracted by the hit time distribution and its consistent with simulations.
- The track can be reconstructed from the drift velocity measurement.

#### correlation between time and strip position



#### track reconstruction in a 5 mm gap





## Project status and schedule



### June 2014: Conceptual Design Report

#### 1. Introduction





- 1. The present BESIII Inner Iracker
- 2. Luminosity Issues
  - 1. Present and expected backgrounds
- 3. Inner Tracker Upgrade Requirements

#### 2. Detector design



- 1. Operating principle of a triple Cylindrical GEM detector
  - 1. The KLOE2 Inner Tracker: know-how and first results
- BESIII CGEM innovations
  - 1. Rohacell
  - 2. Anode design
  - 3. Analog vs. digital, expectations and measurements

#### The BESIII CGEM-IT





- 1. CGEM-IT vs DC-IT
- Mechanical Design
- 3. Tooling and Construction

#### Simulation of Cylindrical GEM Inner Track





- 1. Parametric Simulations (Liang)
- CGEM-IT full Offline Reconstruction
  - 1. Pattern Recognition
  - 2. Tracking
  - 3. Acceptance, Resolutions and Reconstruction Efficiencies
- Monte Carlo simulation results
  - 1. Physics Benchmark

#### 5. Front End Electronics



- 5. Requirements
  - 5. Power Consumption
- 6. System Block Description
- 7. On-Detector Electronics
  - 5. ASIC
- 8. Off-Detector Electronics



#### 6. DAQ and Trigger

- 5. Requirements
- 6. Dead time and bandwidth
- 7. Possible second level trigger future upgrades
- 8. Storage

#### 7. Integration of the CGEM-IT with the Spectrometer

- 5. Mechanical design
  - 5. Interfacing with beam pipe
  - 6. Interfacing with Outer DC
- 6. Power Dissipation and Cooling
- 7. Gas Systems
- 8. HV Systems
- 9. Slow Controls



8. Money, manpower, schedule, task subdivision.....








### External funding

Design, construction and test of a CGEM prototype and readout electronics funded by the Foreign Affairs Ministry agreement of scientific cooperation for a Joint laboratory "INFN-IHEP".



BESIII Winter Collaboration Meeting, Guilin

#### Horizon 2020 MSCA RISE 2014

#### **Proposal Evaluation Form**



#### **EUROPEAN COMMISSION**

Horizon 2020 - Research and Innovation Framework Programme

Evaluation Summary Report

Call: H2020-MSCA-RISE-2014

Funding scheme: Marie Skłodowska-Curie Research and Innovation Staff Exchange (RISE)

Proposal number: 645664
Proposal acronym: BESIIICGEM

Duration (months): 48


Proposal title: An innovative Cylindrical Gas Electron Multiplier Inner Tracker for the BESIII Spectrometer

Criterion 1 - Excellence (weight 50%)

Score: 4.40 (Threshold: 0.00/5.00, Weight: 50.00%)



## Project Schedule





## Summary and Outlook



## Summary and conclusions

- A Cylindrical GEM detector for the upgrade of the BESIII inner tracker has been presented.
- The project aims to design, build and and commission a CGEM-IT by the end of 2017.
- The detector concept is inherited by the KLOE-2 inner tracker with some substantial innovations:
  - lighter mechanical structure
  - different anode electrode
  - analog readout performed by a dedicated ASIC chip
- Data analysis of a test beam with planar prototype is ongoing to exploit the full potential of the GEM technology.
- The project has been recognized as a Significant Research Project within the Executive Program for Scientific and Technological Cooperation between Italy and P.R.C., and recently selected as one of the project funded by the European Commission within the call H2020-MSCA-RISE-2014.



Thanks

